

CONFIRMATION REPORT

BREEAM-NOR-v6.0 (2022)

JOTAPROFF DYNAMIC

supplied by
Jotun A/S

RISE Research Institutes of Sweden AB received from Jotun A/S a product sample which is representative of the manufactured product. It has been tested in accordance with relevant test method (ISO 16000-9:2006), see test report O100152-126199, dated 2021-03-05.

The test results of the tested product prove that the product qualifies for **BREEAM-NOR v6.0 (2022) requirements in Hea 02 Indoor air quality** by complying with:

• **Table Hea 02-01 Emission criteria**

Formaldehyde, TVOC and carcinogens emissions are within the requirements:

	Formaldehyde (mg/m ³)	TVOC (mg/m ³)	Carc. cat 1A&1B (mg/m ³)
Emission criteria	≤ 0.06	≤ 0.3	≤ 0.001
Test results	< 0.005	< 0.010	< 0.001

• **Table Hea 02-02 Exemplary level emission criteria**

Formaldehyde, TVOC, TSVOC and carcinogens emissions are within the requirements:

	Formaldehyde (mg/m ³)	TVOC (mg/m ³)	TSVOC (mg/m ³)	Carc. Cat 1A&1B (mg/m ³)
Exemplary level emission criteria	≤ 0.01	≤ 0.3	≤ 0.1	≤ 0.001
Test results	< 0.005	< 0.010	< 0.005	< 0.001

RISE Research Institutes of Sweden AB
Chemistry and Applied Mechanics- Chemical Product Safety



Maria Rådemar

RISE Research Institutes of Sweden AB

Postal address

Box 857
SE-501 15 BORÅS
Sweden

Office location

Brinellgatan 4
SE-504 62 BORÅS

Phone / Fax / E-mail

+46 10 516 50 00
+46 33 13 55 02
info@ri.se

This document may not be reproduced other than in full,
except with the prior written approval of RISE.

Verification

Transaction 09222115557470066804

Document

O100152-126199-03 Jotaproff Dynamic BREEAM-Nor2022
CONF-report

Main document

1 page

*Initiated on 2022-05-25 11:05:24 CEST (+0200) by Maria
Rådemar (MR)*

Finalised on 2022-05-25 11:05:40 CEST (+0200)

Signing parties

Maria Rådemar (MR)

RISE Research Institutes of Sweden AB

Company reg. no. 556464-6874

maria.rademar@ri.se



Signed 2022-05-25 11:05:40 CEST (+0200)

This verification was issued by Scrive. Information in italics has been safely verified by Scrive. For more information/evidence about this document see the concealed attachments. Use a PDF-reader such as Adobe Reader that can show concealed attachments to view the attachments. Please observe that if the document is printed, the integrity of such printed copy cannot be verified as per the below and that a basic print-out lacks the contents of the concealed attachments. The digital signature (electronic seal) ensures that the integrity of this document, including the concealed attachments, can be proven mathematically and independently of Scrive. For your convenience Scrive also provides a service that enables you to automatically verify the document's integrity at: <https://scrive.com/verify>

